UNCLASSIFIED

AD 288 458


Reproduced by the

ARMED SERVICES TECHNICAL INFORMATION AGENCY
ARLINGTON HALL STATION
ARLINGTON 12, VIRGINIA



UNCLASSIFIED

NOTICE: When government or other drawings, specifications or other data are used for any purpose other than in connection with a definitely related government procurement operation, the U. S. Government thereby incurs no responsibility, nor any obligation whatsoever; and the fact that the Government may have formulated, furnished, or in any way supplied the said drawings, specifications, or other data is not to be regarded by implication or otherwise as in any manner licensing the holder or any other person or corporation, or conveying any rights or permission to manufacture, use or sell any patented invention that may in any way be related thereto.



TRANSLATION

CORROSION OF COPPER AND ITS ALLOYS IN HYDROFLUORIC ACID

By

E. I. Antonovskaya and Yu. N. Vil'k

FOREIGN TECHNOLOGY DIVISION

AIR FORCE SYSTEMS COMMAND

WRIGHT-PATTERSON AIR FORCE BASE OHIO





UNEDITED ROUGH DRAFT TRANSLATION

CORROSION OF COPPER AND ITS ALLOYS IN HYDROFLUCRIC ACID

By E. I. Antonovskaya and Yu. N. Vil'k

English Pages: 6

Source: Khimicheskaya Promyshlennost, No. 6, 1961, pp. 61-62.

SC-1257 SOV/64-61-0-6-3/3

THIS TRANSLATION IS A RENDITION OF THE ORIGINAL FOREIGN TEXT WITHOUT ANY ANALYTICAL OR EDITORIAL COMMENT. STATEMENTS OR THEORIES ADVOCATED OR IMPLIED ARE THOSE OF THE SOURCE AND DO HOT MECESSARILY REFLECT THE POSITION OR OPINION OF THE FOREIGN TECHNOLOGY DIVISION.

PREPARED BY

TRANSLATION SERVICES BRANCH FOREIGN TECHNOLOGY DIVISION WP-AFB, OMO.

FTD-TT-62-724-1+2+4

Date 1 June 19 62

CORROSION OF COPPER AND ITS ALLOYS IN HYDROFLUORIC ACID E. I. Antonovskaya and Yu. N. Vilik

In the manufacture and storage of hydrogen fluoride and its aqueous solution, i.e., hydrofluoric acid, equipment made of copper and its alloys is used [1 through 8]. At the same time, in the literature there are no data on the corrosion of copper and its alloys in boiling hydrofluoric acid.

It is well known that the corrosion of copper and its alloys depends to a considerable degree upon the contamination of the hydrofluoric acid by atmospheric oxygen, and also the presence in it of other oxdizing agents and impurities (H₂SO₄, SO₂, H₂S, H₂O₂, and others). Therefore, we studied first of all the effect of these impurities and of atmospheric oxygen upon the corrosion of M-1 copper and copper alloys BrA5, BrAN and I62 in boiling hydrofluoric acid.

The samples were tested in a laboratory column made of M-1 copper (Figure). Into the 100-ml vessel 1 was poured 40% hydrofluoric acid and heated in an oil bath. The temperature was controlled by a thermoregulator within the limits from 110 to 1140. Six samples, hung on a fluoroethylene-4 tape, were placed in the acid and at the vapor-liquid interface. The system was checked for tightness, and before the experiment was flushed with the gas in which the experiment

was conducted. The duration of the experiments was 100 hours. The admixtures were introduced in the given quantities along with the hydrofluoric acid and their content was analyzed by the methods given in the Technical Specifications of the Ministry of the Chemical Industry 3846--53. The results obtained are given in Tables 1, 2 and 3.

From this data it is apparent that the presence of oxygen in pure hydrofluoric acid has the more negative influence on copper corrosion, especially at the vapor-liquid interface, where corrosion cracking occurred along the boundaries of the crystals as well as through them. Precipitation of copper sponge also took place at the affected places. This effect, the mechanism of which is being studied at the present time, was also noted by Lingnau [9]. In the liquid phase copper corrodes uniformly.

When from 5 to 15% sulfuric acid is added to 40% hydrofluoric acid, the nature of copper corrosion is changed. This, together with other factors, is apparently explained by the change in the ratio of $\rm H_2O$ to HF and the formation of fluosulfonic acid [10, 11], which lowered the corrosive activity of the mixture, and also by the higher boiling point of the mixture at the vapor-liquid interface. Corrosion cracking is reduced, and the corrosion first of all becomes pitting (on addition of 10% $\rm H_2SO_4$), and then uniform (on addition of 15% $\rm H_2SO_4$), but the rate of over-all corrosion is increased.

The presence of H₂S affects copper corrosion more than an admixture of SO₂; cracking becomes greater and the corrosion rate increases. This was noted by Byrne and Vahn [12] for copper in other media. When adding to hydrofluoric acid SO₂ in concentrations encountered in the manufacture of hydrogen fluoride, the corrosion

rate of copper was not increased; the nature of the corrosion also did not change.

When hydrogen peroxide was added, the rate of the over-all corrosion of copper was increased. This is explained by the catalytic decomposition of H_2O_2 on the surface of the copper $(H_2O_2
ightharpoonup H_2O_2)$; the oxygen formed causes the corrosion [13].

The copper alloys BrA5, BrAN and L-62show higher rates of over-all corrosion and corrosion cracking at the vapor-liquid interface than does copper. The corrosion destruction of alloys is accompanied by "dealuminizing" of BrA5 and BrAN and "dezincing" of L-62 brass. In the corrosion of BrA5 it is mainly aluminum that goes into the corrosion products; corrosion cracking and precipitation of copper sponge are observed in the vapor phase and at the vapor-liquid interface at the affected places.

When brass corrodes, a zinc-rich component (β -phase) passes into the acid and cracking and precipitation of copper sponge occur.

Metallographic studies of bronze and brass samples, and also of their corrosion products confirm the results obtained.

Conclusions

- 1. The corrosion rates of M-1 copper, L-62 brass and BrA5 and BrAN bronze in boiling hydrofluoric acid were determined.
- 2. A study was made of the effect of oxygen, H_2SO_4 , SO_2 , H_2S and H_2O_2 upon the corrosion of copper and its alloys in 40% hydrofluoric acid at 110 to 114° .
- 3. It was shown that oxygen, hydrogen peroxide and hydrogen sulfide heighten copper corrosion under the above conditions. In the concentrations studied, SO₂ did not exert a substantial influence on the resistance of the copper. The addition of sulfuric acid im-

proved the nature of copper corrosion, but increased the rate of over-all corrosion.

4. Copper alloys (BrA5, BrAN and L-62) corrode under the cited conditions more vigorously than does M-1 copper.




Figure. Diagram of laboratory apparatus for testing allow samples: 1--vessel; 2--column with water jacket; 3--fluoroethylene-4 gasket; 4--thermocouple housing; 5--test samples.

Table 1
The influence of oxygen on the corrosion rate of M-1 copper in 40% hydrofluoric acid, g/m2 · hr

Gaseous medium	Liquid phase*	Vapor-liquid interface	Nature of corrosion at interface	
Air	3.38	5.90	Corrosion cracking, precipitation of copper sponge	
Nitrogen with:				
3% oxygen	0.19	0.12	n n	
0.02% oxygen	0.05	0.05	Precipitation of copper sponge	

^{*}In the liquid phase corrosion was uniform in all experiments.

Table 2

The influence admixtures on the corrosion rate of M-1 copper in 40% hydrofluoric acid, g/m² · hr (Gaseous medium: nitrogen + 0.02% oxygen)

Admixtures to 40% HF	Liquid phase*	Vapor-liquid interface	Nature of corrosion at interface
Without admixtures	0.05	0.05	Precipitation of copper sponge
5% H ₂ SO ₄	0.14	0.12	Pitting, precipitation of copper sponge
10% H ₂ SO ₄	0.40	0.36	Negligible pitting
15% H ₂ SO ₄	0.61	0.71	Uniform corrosion
0.02% SO ₂	1	0.01	Precipitation of copper sponge
0.21% SO ₂	0.08	0.09	Corrosion cracking, precipitation of copper sponge
0.01% H ₂ S	0.27	0.36	11 11
0.1% H ₂ 0 ₂	1	0.11	Precipitation of copper sponge
0.5% H ₂ 0 ₂	0.81	0.13	Negligible corrosion cracking, precipita- tion of copper sponge
1% H ₂ 0 ₂	1.13	0.49	Corrosion cracking, precipitation of copper sponge

^{*} In the liquid phase corrosion was uniform in all experiments.

Table 3

The corrosion rate of copper alloys in 40% hydrofluoric acid, g/m² · hr

(Gaseous medium: nitrogen + 0.02% oxygen)

Alloy	Liquid phase*	Vapor-liquid interface	Nature of corrosion at interface	
	Pu	re hydrofluoric	acid	
M-1	0.05	0.05	Precipitation of copper sponge	
Bran	0.21	0.06	e n	
BrA5	0.26	0.15	Negligible corrosion cracking	
	Hydrof	luoric acid + 15		
M-1	0.61	0.71	Uniform	
BrA5	0.03	0.05	Corrosion cracking	
L-62**	1.80	2.8	n 11	

*In the liquid phase corrosion was uniform in all experiexperiments.

**Before the experiment the brass samples were annealed at 250° for relief of internal stresses.

REFERENCES

- 1. Ts. A. Adzhemyan. Collection of Articles for the 25th Anniversary of the State Institute of Applied Chemistry, Goskhimizdat, 1944.
 - 2. M. Fontana. Ind. Chemist, 24, No. 287, 801, 1948.
- 3. H. Lux. Anorganische Chemie, Experimentierkunst, Leipzig, 1954.
- 4. M. E. Holmberg and F. A. Prange. Ind. Eng. Chem., 37, 1030, 1945.
 - 5. J. C. Chaston. Chem. Eng., 55, No. 11, 104, 1948.
 - 6. E. Fetter. Chem. Eng., 56, No. 8, 9, 10, 1949.
 - 7. M. Fontana. Ind. Eng. Chem., 39, No. 3, 91A, 1947.
- 8. F. Ritter. Korrosionstabellen metallischer Werkstoffe, Wien, 1947.
 - 9. G. Lingnau. Werkstoffe u. Korrosion, 216, 1957.
 - 10. J. Simons. Fluorine and its Compounds, Vol. 1, IL, 1953.
 - 11. W. Lange. Z. anorg. Chem., 215, 321, 1933.
- 12. J. Byrne and M. D. Vahn. Blast Furnace a. Steel Plant, 41, No. 7, 780, 1953.
- 13. <u>V. McHugh</u>. Hydrogen Peroxide and Peroxide Compounds, IL, 1937.

DISTRIBUTION LIST

DEPARTMENT OF DEFENSE	Mr. Copies	MAJOR AIR COMMANDS	Mr. Copies
	•	AFSC SCFTR ARO	1
HEADQUARTERS USAF		ASTIA TD-Bla	10 3
APCIN-3D2	1	TD-B1b AEDC (AEY) SSD (SSF) BSD (BSF)	3 1 2 1
OTHER AGENCIES		AFFTC (FTY) AFSWC (SWF)	1
CIA MSA AID OTS AEC PWS RAND	1 2 2 2 2 1	TD-B2	1